

Visy Pulp and Paper Tumut CEMS - Correction Log

22/06/2020

Reporting Period: 1/05/2020 - 1/06/2020

Environment Protection Licence No: 10232

Main Stack 1

Monitoring Location No: 1
Monitoring Type: Continuous
Sample Type: Air
Description: Exit point from Stack 1 to atmosphere

Opacity		Period: 6 Minutes	Limit: 20.00 %		
Start Time	End Time	Cause	Operational State	Explanation	Max Reading
31/05/20 14:42	31/05/20 14:48	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.64

Authorised By:

Uday Bhagwat
Pulp Mill Manager



Johan Stoltz
General Manager

