

www.visy.com.au

Air Monitoring Data Report

The attached table summarises the results of emissions testing carried out on the Visy Gas Fired Boilers combined Discharge Stack for the 2021/22 Reporting Period.

Site: Visy Paper Pty Ltd, Smithfield NSW Licence No: 4100

Date of Test: 10 June 2022 Tester: Ektimo Pty Ltd

Report No: R010404 Report Date: 27 June 2022

Table 1: Summary of Average Emission Test Results (Report No. R012785)

Pollutant	Unit of measure	Concentration limit	Result	Complianc
Nitrogen dioxide	mg/m³	250*	3.2	Yes
Nitric oxide	mg/m³	250*	97	Yes
Oxygen	%	N/A	5.9	N/A
Temperature	°C	N/A	102	N/A
Velocity	m/s	N/A	5.2	N/A
Volumetric flow rate	m³/s	N/A	10	N/A
Dry gas density	kg/m³	N/A	1.32	N/A
Moisture	%	N/A	8.5	N/A
Molecular weight stack gases	g/gmol	N/A	29.7	N/A

All results comply with the Environmental Protection Licence emission limits.

Verified by: Date: 29/09/2022

Ben Casauria

Visy National Environment Manager

LP & PAPER