



FOR A BETTER WORLD

6 Herbert Place, Smithfield NSW 2164
Phone +61 2 9794 3120 Facsimile +61 2 9794 3090
Visy Paper Pty Ltd ACN 005 803 234 ABN 49 984 541 896
Visy Pulp and Paper Pty Ltd ABN 30 086 513 144

www.visy.com.au

Air Monitoring Data Report

The attached table summarises the results of emissions testing carried out on the Visy Gas Fired Boilers combined Discharge Stack for the 2018/19 Reporting Period.


Site: Visy Paper Pty Ltd, Smithfield NSW **Licence No:** 4100
Date of Test: 15 March 2019 **Tester:** Ektimo Pty Ltd
Report No: R007348 **Report Date:** 22 March 2019

Table 1: Summary of Average Emission Test Results (Report No. R007348)

Pollutant	Unit of measure	Concentration limit	Result	Compliance
Nitrogen dioxide	mg/m ³	250*	2.8	Yes
Nitric oxide	mg/m ³	250*	86	Yes
Oxygen	%	N/A	3.8	N/A
Temperature	°C	N/A	109	N/A
Velocity	m/s	N/A	7.6	N/A
Volumetric flow rate	m ³ /s	N/A	14	N/A
Dry gas density	kg/m ³	N/A	1.33	N/A
Moisture	%	N/A	15	N/A
Molecular weight stack gases	g/gmol	N/A	29.8	N/A

All results comply with the Environmental Protection Licence emission limits.

Verified by:


Ben Casauria
Visy National Environment Manager

Date:

21 Oct 2019

PULP & PAPER