

Visy Pulp and Paper Tumut CEMS - Correction Log

16/03/2020

Reporting Period:

1/02/2020 - 1/03/2020

Environment Protection Licence No:

10232

Main Stack 1

Monitoring Location No: 1

Monitoring Type: Continuous

Sample Type: Air

Description: Exit point from Stack 1 to atmosphere

Hydrogen Chloride (HCl)		Period: 60 Minutes	Limit: 50.00 mg/Nm ³		
Start Time	End Time	Cause	Operational State	Explanation	Max Reading
11/02/20 16:00	11/02/20 17:00	Instrument Error	Normal (Steady State)	Calibration by Group Instruments	87.58

Authorised By:

Uday Bhagwat
Pulp Mill Manager

Johan Stoltz
General Manager


